

Design Standards Letter

Letter Number: G-1961-37

Letter Date: 05/15/1961

Effective Date: 05/15/1961

Section/Plan No.: None

Subject: Reference to Entrances

Body

May 15, 1961
General Letter No. 37, 1961

Mr. C. C. Tevis

Your attention is directed to the above named letter. We must apologize for the delay in answering, but the letter was not received in this office until May 12, 1961.

We agree that consideration should be given to getting the two Divisions together on the Standard to use for commercial entrances.

We would make the following recommendations regarding this matter:

1. A minimum of 20' and a maximum dimension of 60' at the right-of-way line, be established. It is further recommended that the radii, as shown on Standard Drawing. 21.55 be adopted, with the addition of a 5' radius added at the right -of-way line, where applicable
2. It is further recommended that the adoption of concrete curbing only be considered, in lieu of the curbing and posts now being used by the Maintenance Division.

R. J. Earvin [????}
District Engineer

hbt/ga