

# Design Standards Letter

**Letter Number: G-1975-08**

**Letter Date: 08/22/1975**

**Effective Date: 10/01/1975**

**Section/Plan No.: S0104, S0901**

**Subject: Revised General Special Provisions and Form SP-14**

**Body**

---

ALL DIVISION AND DISTRICT ENGINEERS

Attached are copies of revised Form SP-14 and General Special Provisions.

A brief description of the latest revisions follows:

Section 104: Permits the contractor to submit to the engineer, in writing, proposals for modifying the plans, specifications, etc., for the purpose of reducing the total cost of construction.

Section 901: Discontinues the use of ground rods at lighting poles and provides for the grounding conductor to be connected to the grounding electrode on the supply side at the main disconnect switch.

The above changes are effective with the October, 1975 Letting.

James F. Roberts  
Division Engineer  
Surveys and Plans